

Woodridge Local School District

ACCESSIBILITY CHECKLIST

Check the following to confirm they are in compliance with the accessibility needs of persons with disabilities:

- All entrances and parking areas are properly delineated for access by persons with disabilities.
- Adequate parking spaces are allocated for persons with disabilities.
- Appropriate parking areas are provided for vans transporting persons with disabilities.
- Parking for persons with disabilities is located by the nearest accessible entrance.
- Parking area has an adjacent accessible aisle.
- No curbing interferes with access by persons with disabilities.
- Entry doors have an opening force of no greater than five (5) pounds and are equipped with lever-style or U-shaped door handles.
- Accessible aisles are available throughout the facility.
- Water fountains and telephones are accessible to individuals with wheel-chairs.
- Indoor ramps are equipped with sufficient nonskid material.
- Adequate lavatory facilities are available to persons with disabilities with accessible door latches, sinks, soap and towel dispensers, handrails, toilets, and no exposed piping under sinks.
- Aisles with adequate tables and/or work stations in classrooms and laboratories are accessible to persons with disabilities.
- Libraries/media centers have racks, tables, carrels, service counters accessible to persons with disabilities.
- Aisles, tables, serving areas, disposal areas, and vending areas in lunchrooms are accessible to persons with disabilities.
- Aisles in auditoriums are equipped with nonskid material.
- A visual alarm system is operational for persons with hearing impairments.

1/16/07